

**2025 Annual Drinking Water Quality Report
Consumer Confidence Report (CCR)
Gholson WSC Public Water System ID: TX1550028**

We are pleased to present to you the Annual Water Quality Report (Consumer Confidence Report) for the year, for the period of January 1 to December 31, 2025. This report is intended to provide you with important information about your drinking water and the efforts made by the water system to provide safe drinking water. Este reporte incluye información importante sobre el agua para tomar. Para asistencia en español, favor de llamar al telefono (254) 829-2907.

For more information regarding this report, contact:

Name: Jamie Rager, Office Manager

Phone: (254)829-2907

Sources of Drinking Water

Gholson WSC provides Ground Water from the Trinity Aquifer located in McLennan & Hill Counties. Our water source(s) and source water assessment information are listed below:

Source Name		Type of Water	Report Status	Location
1 - PLANT 1 / WESLEY CHAPEL RD	PLANT 1 / WESLEY CHAPEL RD	Ground water	Active	Well 1 Plant 1 2630 Clater Powell RD Waco, TX 76705
2 - 5 MI N OF PLANT 1	5 MI N OF PLANT 1	Ground water	Active	Well 2 Plant 2 653 HCR 2200 Aquilla, TX 76622
3 - 0.5 MI S OF PLANT 1	0.5 MI S OF PLANT 1	Ground water	Active	Well 3 1441 Wesley Chapel RD Waco, TX 76705
4 - PLANT 3 / STANDPIPE	PLANT 3 / STANDPIPE	Ground water	Active	Well 4 Plant 3 1312 FM 1304 Aquilla, TX 76622
5 - N OF PLANT 1	N OF PLANT 1	Ground water	Active	Well 5 3083 Clater Powell RD Waco, TX 76705

Information about your Drinking Water- The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline at (800) 426-4791. Contaminants that may be present in source water include:

Microbial Contaminants - such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.

Inorganic Contaminants - such as salts and metals, which can be naturally-occurring or result from urban stormwater runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming.

Pesticides and Herbicides - which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.

Organic Chemical Contaminants – including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems.

Radioactive Contaminants – which can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Some people may be more vulnerable to contaminants in drinking water than the general population.

Contaminants may be found in drinking water that may cause taste, color, or odor problems. These types of problems are not necessarily causes for health concerns. For more information on taste, odor, or color of drinking water, please contact the system's business office.

Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

Lead can cause serious health effects in people of all ages, especially pregnant people, infants (both formula-fed and breastfed), and young children. Lead in drinking water is primarily from materials and parts used in service lines and in home plumbing. GHOLSON WSC is responsible for providing high quality drinking water and removing lead pipes but cannot control the variety of materials used in the plumbing in your home. Because lead levels may vary over time, lead exposure is possible even when your tap sampling results do not detect lead at one point in time. You can help protect yourself and your family by identifying and removing lead materials within your home plumbing and taking steps to reduce your family's risk. Using a filter, certified by an American National Standards Institute accredited certifier to reduce lead, is effective in reducing lead exposures. Follow the instructions provided with the filter to ensure the filter is used properly. Use only cold water for drinking, cooking, and making baby formula. Boiling water does not remove lead from water. Before using tap water for drinking, cooking, or making baby formula, flush your pipes for several minutes. You can do this by running your tap, taking a shower, doing laundry or a load of dishes. If you have a lead service line or galvanized requiring replacement service line, you may need to flush your pipes for a longer period. If you are concerned about lead in your water and wish to have your water tested, contact GHOLSON WSC at 254-829-2907. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available at <https://www.epa.gov/safewater/lead>.

A lead service line inventory has been prepared and can be accessed by requesting to review the hard copy located at our water office at 12520 Gholson RD Waco, TX 76705.

In the tables below, you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms, we've provided the following definitions:

<u>Action Level (AL)</u> : The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.
<u>Action Level Goal (ALG)</u> : The level of a contaminant in drinking water below which there is no known or expected risk to health. ALGs allow for a margin of safety.
<u>Level 1 Assessment</u> : A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.
<u>Level 2 Assessment</u> : A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an E. coli MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.
<u>Maximum Contaminant Level or MCL</u> : The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
<u>Maximum Contaminant Level Goal or MCLG</u> : The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

<u>Maximum residual disinfectant level goal or MRDLG</u> : The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
<u>Maximum residual disinfectant level or MRDL</u> : The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
<u>Treatment Technique or TT</u> : A required process intended to reduce the level of a contaminant in drinking water.
<u>Variations and Exemptions</u> : State or EPA permission not to meet an MCL or a treatment technique under certain conditions.
<u>Avg</u> : Average - Regulatory compliance with some MCLs are based on running annual average of monthly samples.
<u>RAA</u> : Running Annual Average.
<u>LRAA</u> : Locational Running Annual Average.
<u>mrem</u> : millirems per year (a measure of radiation absorbed by the body).
<u>ppb</u> : micrograms per liter (ug/L) or parts per billion - or one ounce in 7,350,000 gallons of water.
<u>ppm</u> : milligrams per liter (mg/L) or parts per million - or one ounce in 7,350 gallons of water.
<u>picocuries per liter (pCi/L)</u> : picocuries per liter is a measure of the radioactivity in water.
<u>na</u> : not applicable.

Disinfectant Residual

All public water systems in Texas are required to disinfect drinking water to ensure control of microbial contaminants. Disinfectants are water additives used to control microbes.

Disinfectant	Year	Average Level	Unit	Range	MRDL/MRDLG Goal
Chlorine Gas	2025	1.47	ppm	0.2-2.05	4/4

Regulated Contaminants

In the tables below, we have shown the regulated contaminants that were detected. Chemical Sampling of our drinking water may not be required on an annual basis; therefore, information provided in this table refers back to the latest year of chemical sampling results.

Lead and Copper	Period	90TH Percentile: 90% of your water utility levels were less than	Range of Sampled Results (low - high)	Unit	AL	Sites Over AL	Typical Source
COPPER, FREE	2023 - 2025	0.1049	0 - 541	ppm	1.3	1	Corrosion of household plumbing systems; Erosion of natural deposits; Leaching from wood preservatives
LEAD	2023 - 2025	0	0	ppb	15	0	Corrosion of household plumbing systems; Erosion of natural deposits

Disinfection Byproducts	Sample Point	Period	Highest LRAA	Range	Unit	MCL	MCLG	Typical Source
TOTAL HALOACETIC ACIDS (HAA5)	1042 HCR 2200, GHOLSON	2025	0	0	ppb	60	0	By-product of drinking water disinfection
TTHM	613 RIVER RD, GHOLSON	2025	5	4.7	ppb	80	0	By-product of drinking water chlorination

Regulated Contaminants	Collection Date	Highest Value	Range	Unit	MCL	MCLG	Typical Source
BARIUM	9/10/2025	0.0547	0.0517 - 0.0547	ppm	2	2	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits
DIBROMOCHLOROMETHANE	9/10/2025	2.2	0 - 2.2	UG/L	0	0.06	
FLUORIDE	5/21/2024	0.8	0.8	ppm	4	4	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories

Radiological Contaminants	Collection Date	Highest Value	Range	Unit	MCL	MCLG	Typical Source
COMBINED RADIUM (-226 & -228)	6/17/2021	1.5	1.5	pCi/L	5	0	Erosion of natural deposits

Violations

During the period covered by this report we had the below noted violations.

Violation Period	Analyte	Violation Type	Violation Explanation
1/1/2023 - 12/31/2025	LEAD & COPPER RULE	FOLLOW-UP OR ROUTINE TAP M/R (LCR)	Failed to comply with follow-up or routine tap monitoring requirements related to lead and copper

Public Participation Activities: Please visit our website gholsonwsc.myruralwater.com for more information about public participation in decisions that may affect the quality of water.

Gholson WSC holds Board Meetings each month on the 1st Monday of every month at 6:00pm in the office located at 12520 Gholson RD. Waco, TX 76705.

There are no additional required health effects notices.

There are no additional required health effects violation notices.

IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER

Gholson Water Supply Corporation has violated the monitoring and reporting requirements set by Texas Commission on Environmental Quality (TCEQ) in Chapter 30, Section 290, Subchapter F. Even though these were not emergencies, as our customers, you have the right to know what happened and what we are doing (or did) to correct these situations.

We are required to monitor your drinking water for specific contaminants on a regular basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. During June 1st- September 30th, 2025, did not complete all monitoring or testing for lead and copper tap water sampling and therefore cannot be sure of the quality of your drinking water during that time.

The table below lists the contaminant(s) we did not properly test for during the last year, how often we are supposed to sample for [these contaminants], how many samples we are supposed to take, how many samples we took, when samples should have been taken, and the date on which the follow-up samples were [or will be] taken.

Contaminant	Required sampling frequency	Number of samples taken	When samples should have been taken	When samples were or will be taken
Lead and copper tap water sampling	Yearly	10 Samples taken. 20 Samples Required	6/1-9/30/2025	6/1-9/30/2026

What is being done?

We are working to correct the problem. For more information, please contact Jamie Rager at (254)829-2907 or 12520 Gholson RD Waco, TX 76705.

During the June 1st- September 30, 2025, lead and copper tap monitoring period, we only collected 10 samples. We are required to collect 20 samples. We are scheduled to complete lead and copper tap monitoring during the June 1st-September 30th, 2026 monitoring period.

This notice is being sent to you by Gholson WSC 12520 Gholson RD. Waco, TX 76705. Public Water System Number: TX1550028
Date Distributed: June 10, 2026